| LUVAIA | L | U | V | Ά | | Ά |
|--------|---|---|---|---|--|---|
|--------|---|---|---|---|--|---|

| Customer: | | Date: | 9/29/2009 |
|------------|---|-------------|-----------|
| Contact: | | From: | |
| Telephone: | | Company: | |
| Cell: | | Return Tel: | |
| Fax: | | Return Fax: | |
| Job: | | | |
| Quote #: | 0 | | |

GIVEN DATA

| <u>Construction</u> | | <u>Air Side</u> | |
|---------------------|-----------------|---------------------------|---------------|
| Item: | DXM3-4 | Air Flow (Sft^3/min) | 7,000 |
| Coils Per Bank: | 1 | Altitude ft: | .00 |
| Tube OD IN: | 5/8 | Ent. Air DB/WB °F: | 95.00 / 78.00 |
| Style: | EJ | Lvg. Air DB/WB | .00 / .00 |
| Fins Per Inch: | 13 | Total / Sensible MBH: | 360.0 / .00 |
| Rows: | 3 | Max Air PD "H2O: | .00 |
| Fin Surface: | В | | |
| Fin Height (IN): | 43.50 | Refrigerant Side | |
| Finned Length (IN): | 42.00 | Refrigerant: | 410A |
| Tubing Mat. (IN): | 0.020 Copper | Super Heat °F: | 8.00 |
| Fin Mat. (IN): | 0.0075 Aluminum | Saturated Suction Temp F: | 45.00 |
| Circuiting: | Optimize | Liquid Temp | 110.0 |
| Face Area (SQ FT): | 12.69 | | |

| OUTPUT DATA | | M | lost Economic | al | Specified Coil | | | |
|-----------------|-----------|--------|---------------|--------|----------------|--------|--------|--|
| | | Coil 1 | Coil 2 | Coil 3 | 🧹 Coil 4 | Coil 5 | Coil 6 | |
| Model Number: | | | | | 5EJ1303B | | | |
| Air Velocity: | (Sft/min) | | | | 551.7 | | | |
| Total Capacity: | MBH | | | | 353.3 | | | |
| Sens. Capacity: | MBH | | | | 207.8 | | | |
| Lvg. Air DB: | ۴ | | | | 67.52 | | | |
| Lvg. Air WB: | ۴ | | | | 65.36 | | | |
| Standard APD | "H2O | | | | .51 | | | |
| Code 18 / 19: | | | | | 8014/15 | | | |
| Suction Conn.: | IN | | | | (2) 2.125 | | | |
| Liquid Conn 1: | IN | | | | (2) 1.125 | | | |
| Liquid Conn 2: | IN | | | | N/A | | | |
| Refg. PD: | lbf/in^2 | | | | 1.57 | | | |
| Refg. Velocity: | ft/min | | | | 1,321 | | | |
| Weight: | lbm | | | | 164.6 | | | |
| Notes: | | | | | BCGJKMQ | | | |
| | | | | | | | | |
| | | | | | | | | |

Notes:

B) Rated In Compliance With ARI 410.

C) Coil Not Within Certified ARI Directory.

G) Load below specification. Consult factory.

K) Special Circuiting, Dead Tubes May Be Required, Consult Factory. M) Coil rating valid for Heatcraft coils only.


Q) If evaporator is used in a heatpump application, change tubing material to 5/8 Stainless Steel or 5/8 Carbon Steel or select a 3/8 OD coil.

J) Coil Will Be Supplied With Multiple Distributors.

HEATCRAFT CERTIFIED DRAWING

| Customer: | | Date: | 9/29/2009 |
|------------|---|-------------|-----------|
| Contact: | | From: | |
| Telephone: | | Company: | |
| Cell: | | Return Tel: | |
| Fax: | | Return Fax: | |
| Job: | | | |
| Quote #: | 0 | | |

| | | | | | М | ODEL NU | MBER | | | | | |
|--------------------|---------------|--------------|-------------------------|------------|----------|-----------|----------------|---------------|--------------------|----|----------------|--|
| ITEM | | QTY | TYPE | FPI | ROW | S FIN | FH (IN) | FL (IN) | HA | ND | | |
| DXM | 3-4 | 1 | 5EJ | 13 | 03 | В | 43.50 | 42.00 | 42.00 Left | | | |
| MATERIALS | OF CONSTRUCTI | ON | | OPTIONS | | | | | | | | |
| Fins 0.0075 Alumin | | านm | Coating | | | None | | Nitrogen | Charge | No | | |
| Tubes | 0.020 Copper | 0.020 Copper | | Туре | | Flanged | | Moisture | Moisture Elimnator | | | |
| Casing | Galvanized St | teel | Bypass | Kit Size | I | None | ° | | Mounting Holes | | Mounting Holes | |
| Conn. Material | Copper | | | itor Loca | | | | Label Kit | Label Kit | | | |
| Conn. Type | Sweat | | Distributor Tube 0.3125 | | | | | | | | | |
| Conn. Size | 1.625/1.125 | | Nozzle | Number | | 12 | | | | | | |
| | | | Number | r of Circu | uits (| 14 | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | LEFT HA | ND | | |
| → | ← N | _ | | S | ↑ | | → J ← ← M → | - F | ← W | + | | |



| | DIMENSIONAL DATA(IN) | | | | | | | | | | | |
|-------|----------------------|------|-------|------|------|------|------|------|------|-----|--|--|
| | | | | | | | | | | | | |
| Н | I | J | L | М | N | R | S | Т | W | SJC | | |
| 46.50 | 50.50 | 6.00 | 45.00 | 5.25 | 3.25 | 1.50 | 1.50 | 1.50 | 7.50 | | | |

NOTES:

GENERAL NOTES:

- 1. All dimensions are in inches.
- 2. Phenolic coated coils require a longer lead-time since they must be re-tested after coating.
- 3. .375 inch mounting holes will be provided on 6 inch centers from the centerline of the fin height and finned length. Not available when S < 0.75 inches.
- 4. The suction line should be connected to the lower connection on

The solution line should be connected to the level series series and the exclusive and confidential use of Luvata Grenada LLC and its client. Any duplication made for the purpose of disclosing this design or any part of the design to a competitor of Luvata Grenada LLC is in direct violation of this confidentiality. Any duplication must be approved in writing by Luvata Grenada LLC.
Page 31